

DISTRICT MANAGER-ENGINEER
MARK THOMAS & COMPANY, INC.
DAVID E. ROSS

DISTRICT COUNSEL
ATKINSON • FARASYN, LLP.
HAROLD S. TOPPEL



20833 STEVENS CREEK BOULEVARD, SUITE 104
CUPERTINO, CALIFORNIA 95014-2154
(408) 253-7071 PHONE • (408) 253-5173 FAX
www.cupertinosanitarydistrict.com

BOARD OF DIRECTORS
STEPHEN C. ANDREWS
WILLIAM A. BOSWORTH
JOHN M. GATTO
CURTIS B. HARRISON
WENDELL H. KERR, JR.

June 13, 2006

Grease Interceptor Requirements:

1. Sample Box.
2. Manholes at each end and center baffles located over plumbing fittings. The complete floor shall be visible from the manhole openings.
3. Manhole Covers shall be 24" in Diameter.
4. Pipe Fittings shall be 4" SDR 35 PVC.
5. Manhole Adjusting Rings not to exceed twelve inches (12"). For deep installations contact the District Engineer for design approval.

Grease Interceptor Installation Requirements:

1. Interceptor to be IAPMO approved.
2. Installed to manufacturer's specification's and all work shall comply with all current local, state and federal requirements.
3. Interceptor Cover and Manhole Risers to be sealed.
4. Interceptors to be vented away from all HVAC or other building fresh air intakes.
5. Pre-Test Observation by District prior to backfilling.
6. Testing: Cupertino Sanitary District requires a Vacuum Test In addition to tests required of the local jurisdiction, tests to be conducted in accordance with the manufacturer's specifications and all equipment required is the responsibility of the owner.

Grease Interceptor Operation and Maintenance:

1. Property Owner Responsible for ALL Interceptor Operations, Maintenance and Repairs.
2. Pumping required every Ninety (90) Days, or as approved by the District Manager-Engineer, not to exceed manufacturer's specifications.
3. Inspection of all fittings Every Time interceptor is pumped.
4. Records of pumping required to be maintained by the Tennant and Owner for a minimum of Three (3) Years.
5. Emergency Plan to be prepared by Owner. As a minimum the plan is to explain the emergency procedures to be followed by on site staff until professional assistance takes control of the problem. The plan should provide for the protection of employees, customers, property and all storm drains. In addition it should list the telephone numbers of the following:

Emergency Pumping
Facility Manager or Maintenance Manager
Cupertino Sanitary District
Emergency Cleanup Service/Contractor